Notes:	** Ceiling sheeting to the Health Centre, common to adjacent Classroom -* ***Chrysotile Asbestos fibre detected***									
Humanities	Upper level	External	Wall	Yes	76	Yes		Asbestos Cement	Average	4
Notes:	** External wall sheeting to the upper level of the Building -* ***Chrysotile Asbestos fibre detected***								REINSPECTION REQUIRED	
Humanities	Roof level	External	Eaves/Gables	No		Yes		Asbestos Cement	Average	4
Notes:	** The eaves & gable lining to the building* ***is suspected to contain Asbestos fibre****.*								REINSPECTION REQUIRED	