

BUILDING ID	LOCATION			SAMPLE TAKEN		SUSPECTED		PRODUCT TYPE	CONDITION	PRIORITY
	Elevation	Locality	Position	Yes/No	No.	Yes	No			
McKeague Hall	Level 1	Internal	Wall	Yes	18	Yes		Vinyl	Average	4
<i>Notes:</i> * <u>Vinyl</u> splashbacks to the walls in the Junior Science Labs – No Asbestos Fibre Detected. NOT FOUND 10/04/2024 <u>However</u> the wall sheeting to the Science Labs contains Chrysotile Asbestos fibre & readily separates when removing the vinyl from the wall.										
McKeague Hall	Level 1	Internal	Wall	Yes	19	Yes		Asbestos Cement	Average	4
<i>Notes:</i> * <u>Internal</u> wall sheeting to Junior Science Labs & Office ,also common to the <u>verandah</u> – Chrysotile Asbestos fibre detected. NOT FOUND 10/04/2024										
McKeague Hall	Level 1	Internal	Ceiling	Yes	20	Yes		Asbestos cement	Average	4
<i>Notes:</i> * <u>Ceiling</u> sheeting to Junior Science Labs & Office, also common to the <u>verandah</u> - Chrysotile Asbestos fibre detected. NOT FOUND 10/04/2024										
McKeague Hall	Level 1	Internal	Fume Cupboard	Yes	21	Yes		Asbestos Cement	Average	4
<i>Notes:</i> * <u>Flue</u> to exhaust fume cupboard in Junior Science Lab – Chrysotile & Amosite Asbestos fibre detected. NOT FOUND 10/04/2024 <u>Note:</u> The splashback sheeting located internal and to the back of the fume cupboard is suspected to contain Asbestos fibre										
McKeague Hall	Ground, 1 & 2	External	Columns	Yes	22	Yes		Asbestos Cement	Average	4
<i>Notes:</i> * <u>External</u> mouldings & cover sheeting to columns both sides of the building - Chrysotile Asbestos fibre detected. NOT FOUND 10/04/2024										
McKeague Hall	Level 2	Internal	Floor	Yes	23			Vinyl	Average	4
<i>Notes:</i> * <u>Vinyl</u> tile to Room S3, common to other 2 laboratories this level - No Asbestos Fibre Detected.										
McKeague Hall	Level 2	Internal	Storage Drawers	Yes	24	Yes		Insulation	Poor	1
<i>Notes:</i> * <u>Thermal</u> insulation to wire mats (Bunsen burners) stored in drawers in Labs - Chrysotile Asbestos fibre detected. NOT FOUND 10/04/2024										